

Attestation

BREEAM®

On the 16th of June 2023 Eurofins Product Testing A/S received a sample of a paint with the product name:

MAGNUM MURI LUCIDO

supplied by

Boero Bartolomeo S.p.A.

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 11890-2 testing standards (See test report no. 392-2023-00480606_A_EN and 392-2023-00480612_XG_EN).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions and VOC content by complying with:

- **BREEAM® International: Compliance with 'Exemplary' criteria on both VOC emission and VOC content** of BREEAM International: New Construction 2021, Technical Manual – SD250: Hea 02 Indoor Air Quality (version 6.0. of December 2021).
- **BREEAM® UK: Compliance with 'Exemplary' criteria on both VOC emission and VOC content** of BREEAM UK: New Construction 2023, Technical Manual: Hea 02 Indoor Air Quality (version SD5079 issue 6.1 of June 2023).
- **BREEAM® NL: Compliance with 'Exemplary' criteria on both VOC emission and VOC content** of BREEAM NL: Nieuwbouw 2020, Technical Manual: Hea 02 Interne Luchtkwaliteit (Version 1.0 of June 2020).
- **BREEAM® SE: Compliance with 'Exemplary' criteria on both VOC emission and VOC content** of BREEAM SE: New Construction 2021, Technical Manual: Hea 02 Indoor Air Quality (version 6.0. of January 2023).
- **BREEAM® NOR: Compliance with 'Exemplary' criteria on both VOC emission and VOC content** of BREEAM NOR: New Construction 2022, Technical Manual – SD5076NOR, Hea 02 Indoor Air Quality (version 6.0 of February 2022).

21 December 2023



Henriette Buch Lauersen
Analytical Service Manager



Laura Hartung Sørensen
Analytical Service Manager