

Boero Bartolomeo S.p.A.  
 Direzione HR & Innovation -  
 Via Macaggi, 19  
 16121 GENOVA  
 ITALY

Eurofins Product Testing Denmark A/S  
 Smedeskovvej 38  
 8464 Galten  
 Denmark

CustomerSupport@eurofins.com  
 www.eurofins.com


## VOC EMISSION TEST REPORT

### Indoor Air Comfort GOLD

#### 1 Sample Information

Sample name	BOERO HP SATINATO
Batch no.	72401082
Stated production date	26/04/2024
Product type	Paint
Sample reception	21/05/2024

#### 2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation §		Decree of March 2011 (DEVL1101903D) and Arrêté of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A)
French CMR components §	Pass	Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A)
Italian CAM Edilizia	Pass	DM 23 giugno 2022 n. 256, GURI n. 183 del 6 agosto 2022
ABG/AgBB	Pass	Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (June 2021)
Belgian Regulation	Pass	Royal decree of May 2014 (C-2014/24239)
Indoor Air Comfort	Pass	Indoor Air Comfort 9.0 of June 2023
Indoor Air Comfort GOLD	Fail	Indoor Air Comfort GOLD 9.0 of June 2023
Blue Angel (DE-UZ 12a)	Pass	DE-UZ 12a for "Low-emission and low-pollutant paints and varnishes", January 2019
EU Taxonomy	Pass	Regulation (EU) 2020/852 of the European Parliament and of the Council

Full details based on the testing and direct comparison with limit values are available in the following pages  
 Regarding pass/fail decision rule please see appendix  
 § See section 4.4 on deviations

  
**Frederik Foged Haugaard**  
 Analytical Service Manager

  
**Laura Hartung Sørensen**  
 Analytical Service Manager

The analysis are carried out on the sample(s) as received and the result(s) are only valid for the tested sample(s).  
 This report may only be copied or reprinted in its entirety.