

Boero Bartolomeo S.p.A.
 Direzione HR & Innovation -
 Via Macaggi, 19
 16121 GENOVA
 ITALY

Eurofins Product Testing Denmark A/S
 Smedeskovvej 38
 8464 Galten
 Denmark

CustomerSupport@eurofins.com
 www.eurofins.com

VOC EMISSION TEST REPORT


Indoor Air Comfort GOLD

31 July 2024

1 Sample Information

Sample name	FONDO 2000
Batch no.	72400836
Stated production date	09/04/2024
Product type	Paint
Sample reception	21/05/2024

2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation §		Decree of March 2011 (DEVL1101903D) and Arrêté of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A)
French CMR components §	Pass	Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A)
Italian CAM Edilizia ABG/AgBB	Pass	DM 23 giugno 2022 n. 256, GURI n. 183 del 6 agosto 2022
Belgian Regulation	Pass	Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (June 2021)
Indoor Air Comfort	Pass	Royal decree of May 2014 (C-2014/24239)
Indoor Air Comfort GOLD	Pass	Indoor Air Comfort 9.0 of June 2023
Blue Angel (DE-UZ 12a)	Pass	Indoor Air Comfort GOLD 9.0 of June 2023
EU Taxonomy	Pass	DE-UZ 12a for "Low-emission and low-pollutant paints and varnishes", January 2019
		Regulation (EU) 2020/852 of the European Parliament and of the Council

Full details based on the testing and direct comparison with limit values are available in the following pages
 Regarding pass/fail decision rule please see appendix
 § See section 4.4 on deviations


 Frederik Foged Haugaard
 Analytical Service Manager


 Laura Hartung Sørensen
 Analytical Service Manager

The analysis are carried out on the sample(s) as received and the result(s) are only valid for the tested sample(s).
 This report may only be copied or reprinted in its entirety.

392-2024-00241803_A_EN

Page 1 of 23